



P.O. Box 129, 1 Bailey Street, Port Carling, Ontario, P0B 1J0
Website: www.muskokalakes.ca
Phone: 705-765-3156
Fax: 705-765-6755

Tender Addendum 2

Tender
Milford Bay Road Bridge Replacement
Milford Bay Road Bridge

Tender No.
T-2021-11

Date
March
18, 2021

Owner
Township of Muskoka Lakes

Message to Bidder

Question 1

The tender documents indicate that HL4 surface asphalt is to be placed at 40mm thickness throughout the limits of the contract however the contract documents indicate 50mm HL4 on top of the culvert approach slabs (drawing S-6). Should the HL4 on the approach slabs be 40mm? if not and 50mm is correct is there a ramping detail as the approach slab and the distribution slab are at the same elevation and ramping will be required for the 10mm difference in elevation between the Culvert distribution slab and approach slabs as well as the approach slabs and road beyond the approach slabs.

Answer 1

HL4 surface asphalt thickness shall be 40 mm throughout the limits of the Contract, including over the approach slabs

Question 2

The contract documents do not indicate the Asphalt Cement grade, can you please confirm the acceptable AC grade.

Answer 2

Asphalt Cement shall be PGAC 58-34.

Terms & Conditions

Except as to and to the extent that they are amended by the foregoing, all terms and conditions of the tender document remain in full force and effect, and time shall be of the essence.

Directions to Bidder

The Bidder shall:

1. sign this Addendum in the space provided below and submit this Addendum to the Owner in the same envelope as the Tender
2. enter this Addendum number in the Tender Form

Signature of Bidder

Date