



---

## ADDENDUM

## NO. 1

PROJECT: Raymond Community Centre, Washroom Addition /  
Renovations, Muskoka Lakes Township

PROJECT No: 19-36

DATE: November 14, 2022

BUILDING PERMIT NO:

---

This addendum is issued to make corrections required on the documents, add to the documents, or clarify the documents.

---

### ITEMS:

1. Question: Can you have someone find out the specs on the septic tank to be relocated? IE (tank volume, material – concrete or plastic, dimensions, weight, condition etc?)

**Answer: Tank volume is 18,000 litres, material is concrete, approximately 102" wide x 192" long x 86" deep (not including risers). Assume that the tank was originally installed in two segments. Assume an approximate weight of 36,000 pounds, total. The tank was installed in 2009 - assume that it is in a condition acceptable for moving.**

2. The Township of Muskoka Lakes will arrange to have the septic tank pumped out prior to the start of construction.

Issued by:

---

for Duncan Ross Architect