



# **Township of Muskoka Lakes**

## **Request for Tender**

**T-2023-18**

### **Removal and Replacement of Fuel System at Ranwood Yard**

---

**ADDENDUM # 2**

**Aug 28, 2023**

---

The following addendum shall now form part of the contract documents and amends the applicable information contained in the original contract tendering documents.

All other information contained in the original tendering documents remains unchanged.

**T-2023-18 ADDENDUM # 2**

**Aug 28, 2023**

---

**Section of Document Amended:**

**SP-F-1, Section 2.1**

**Instructions:**

**The minimum size of the new diesel tank is changed from 8,850L to be 8,800L. All other tank requirements remain the same.**

---

**Directions to Bidder:**

The Bidder shall:

1. Sign this Addendum in the space provided below and submit this Addendum to the Owner in the same envelope as the Tender
2. Enter this Addendum number, date and number of pages on the Tender submission (Part III – Form of Tender Section 1.1.f, page A-8)

---

Signature of Bidder

Date