



P.O. Box 129, 1 Bailey Street, Port Carling, Ontario, P0B 1J0
tel: 705-765-3156 fax: 705-765-6755 web: www.muskokalakes.ca

PROPOSAL ADDENDUM 2

File	Tender	Tender No.
	Architectural Drawings & Soil Samples Port Carling Arena Floor	P-2020-21
Date	Owner	
July 13, 2020	Corporation of the Township of Muskoka Lakes	

Message to Bidder

Please see Addendum 1 for the schedule changes for the RFP. This Addendum addresses the concerns of Bidders having to secure, and be responsible for the Refrigeration component of this summer' project.

- i. **Section three (3); subsection 36 ii) for the Request for Proposal states-** Hire a Refrigeration Contractor to pump out the brine from the Secondary Refrigerant system. Successful Contractor will pump out the brine from the Arena's Secondary refrigerant system under the floor and store on site. Test holes (minimum of four) will be cut/chipped and soil samples tested to determine the quality and depth of granular soil. The polyethylene piping will be spliced, clamped, and refilled with Quick Crete 5000. The brine will be pumped back into the system removing any air, and testing for leaks prior to filling in the test holes with Quick Crete 5000. **The successful bidder will not be responsible for the services of a Refrigeration Company, or the concrete work.**
- ii. **Notice**** The Township of Muskoka Lakes will tender out the necessary work to pump out the brine from the floor (1,800 gallons), cut out the test holes for the soil samples, splice the polyethylene pipes, pump the brine back in (including testing for air and leaks). The successful bidder will be responsible for obtaining the services of the geotechnical engineers for taking the necessary soil samples.
- iii. The Consultant will provide assistance during the tender period in the form of answering technical questions and preparation of addenda if

required. Part of the recommendation will be to determine the number of test holes, and the location of these test holes (to remove the soil samples).

Terms & Conditions

Except as to and to the extent that they are amended by the foregoing, all terms and conditions of the proposal document remain in full force and effect, and the time shall be of the essence.

Direction to Bidder

The Bidder shall:

- 1) Sign this Addendum in the space provided below and submit this Addendum to the Owner in the same envelope as the Proposal.
- 2) Enter this Addendum number in the Proposal Form (page 32).

Signature of Bidder

Date