



Township of Muskoka Lakes

Request for Tender

T-2026-28

Removal and Replacement of Fuel System at Patterson Yard

ADDENDUM # 4

July 20, 2026

The following addendum shall now form part of the contract documents and amends the applicable information contained in the original contract tendering documents.

All other information contained in the original tendering documents remains unchanged.

T-2026-28 ADDENDUM # 4

July 20, 2026

Directions to Bidder:

Addendum #3 is deleted in its entirety and replaced with the following Addendum #4.

Subsection 4.4 of Section “TC-4 Addenda” within “Part II – Tender Conditions” is amended as follows:

The deadline for the posting of addenda is 5:00 pm on Monday, July 20, 2026 or as amended by addendum.

For further clarification, the following information has been supplied:

The existing ASI ASPC Box currently is not configured for two dual fuel dispensers at this site and requires additional relays. An additional ASI R4U Relay Module with wiring needs to be added in ATTENDANT APSC Box. The Contractor shall be responsible for supply and installation of this module. The work shall include the upgrade of any required equipment as well as the setup and commissioning of the new system to operate with the Township’s existing Winfuel Software. As per the tender documents ASI shall be contacted to determine full construction requirements and the Contractor shall be responsible for coordinating with ASI for installation and commissioning of the new system as part of the work.

The Bidder shall:

1. Sign this Addendum in the space provided below and submit this Addendum to the Owner in the same submission package as the Tender
2. Enter this Addendum number, date and number of pages on the Tender submission (Part III – Form of Tender Section 1.1.f, page A-8)

Signature of Bidder

Date